

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 3774-0544:105 Page 1 of 1

CATEGORY: Electric Locks

LISTEE: Locknetics, 575 Birch Street, Forestville, CT 06010
Contact: *Adam O'Day (860) 314-5248 Fax (860) 314-2452

DESIGN: Special locking arrangement, Models 101, 101-2, 101-SC, 101-2SC, 101+ , 101+ -2, 101+ -2SC; 103, 103-LM, 105, 105-2, 107, 107-DB, 107-2, 109, 109-TJ, 109-DB, 109-2, 301+ , 301+ PS and 505DE.

Refer to listee's data sheet for additional detailed product description and operational considerations.

RATING: 120 VAC, 12, VDC or 24 VDC

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating and UL label.

APPROVAL: Listed as electromagnetic door locks for use with swinging and sliding type fire doors as a mean of supplemental locking of the door in addition to the door's required latching mechanism when installed in accordance with the Uniform Building Code, Section 1004.5 Special Egress-Control Devices. Authority having jurisdiction shall be consulted prior to installation.

*Rev. 05-16-2002



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

MAY 30, 2002

*Listing Expires **June 30, 2003***

Authorized By:

DIANE K. AREND, Senior Deputy
Program Manager